

**ORISSA ELECTRICITY REGULATORY COMMISSION  
BIDYUT NIYAMAK BHAWAN  
UNIT-VIII, BHUBANESWAR – 751 012  
\*\*\*\*\***

**Present :      Shri B.K. Das, Chairperson  
                     Shri S.K. Jena, Member**

*Dated the 15<sup>th</sup> March, 2008*

**Case No.9 of 2008**

M/s. OCL India Ltd.  
Plot No.1129, Near Moon Hospital,  
Mahanadi Vihar, Cuttack

...

**Petitioner**

- Vrs. -

Orissa Power Transmission Corporation Ltd. (OPTCL) ...  
Janpath, Bhubaneswar

**Respondent**

For the petitioner      : Mr. R. Pandey, Asst. Executive Director of the  
   petitioner company

For the respondent    : Mr. J.P. Das, Sr. G.M. (R&T), OPTCL

**ORDER**

M/s OCL India Ltd. (Kapilas Cement Works), the petitioner in this case has put up a Cement Plant at village Biswali, P.O. Barunia, Dist. Cuttack. The power supply to its unit is to be taken through LILO arrangement from the existing 132 KV S/C ICCL-Salipur line to its switching substation at Biswali. The electrical inspection is completed. Part installation and testing of PLCC link between OCL to ICCL has been completed. Installation of data acquisition system equipment (RTU) has been completed but not commissioned. The petitioner has furnished an undertaking to the respondent to complete the balance installation and commissioning and has requested for early energization of its switching substation. The petitioner submits that since it shall have no power plant, installation of PLCC is required but not strictly the SCADA. However, the petitioner has

prayed that it may be allowed relaxation under Reg.1.8 of the OGC to energize the line and substation pending completion of the PLCC/SCADA commissioning.

2. M/s OPTCL, the respondent submits that it received the copy of the petition on yesterday only and is therefore not in a position to furnish any comment. However, if the Commission so desires, relaxation of time may be allowed to the petitioner to put PLCC and SCADA and synchronization may be allowed.

3. In exercise of the power under Regulation 1.8 of the OGC, the Commission directs synchronization of the line and substation of the petitioner with the state grid which will allow early energization and earning of revenue for the State's power sector and Electricity Duty to the State. The petitioner is directed to complete the commissioning of PLCC/SCADA within 2 months.

4. Before parting, we would observe that industries putting up large industries with EHT interconnection need to take appropriate professional guidance for observation of codal provisions so as to avoid delays in commission of new projects which, otherwise, means a national loss. Besides Electricity Utilities like OPTCL and DISTCOs should also suitably advise the upcoming new consumers so that petitions of these nature shall not come before the Commission.

Accordingly the case is disposed off.

Sd/-  
**(S.K. Jena)**  
**Member**

Sd/-  
**(B.K. Das)**  
**Chairperson**