ODISHA ELECTRICITY REGULATORY COMMISSION BIDYUT NIYAMAK BHAWAN, PLOT NO-4, CHUNUKOLI, SHAILASHREE VIHAR, CHANDRASEKHARPUR, BHUBANESWAR - 751 023.

Present: Shri S. P. Nanda, Chairperson

Shri S.P. Swain, Member Shri A.K. Das, Member

Case No. 74/2009

Shri Laxmidhar Chakra & others

. Petitioners

Vrs.

The S.D.O (Electrical),

Anandpur Electrical Sub-Division, NESCO & others.

.. Respondent

In the matter of: An application u/Ss.142, 146 &147 of the Electricity Act, 2003.

ORDER Date of Order:08.07.2016

Shri Laxmidhar Chakra and the villagers have filed a common petition in the above noted case under Sections 142, 146 & 147 of the Electricity Act, 2003 for non-implementation of the order dated 24.06.2008 of the GRF, Jajpur Road passed in C.C.Case No. 129/2008 and also order dated 12.11.2008 of the Ombudsman-II passed in C.R.Case No. OM (II)-13/2008.

The Commission had heard the matter on 19.06.2009 and passed the following directions "After hearing the parties and perusal of the case records, the Commission directs the CEO, NESCO to make a field inquiry on the above matter along with a Technical Committee and make suitable recommendations on the remedial measures required, both short term and long term to the Commission by 31st July, 2009."

- 2. The CEO, NESCO was further directed vide interim order dated 13.11.2009 of the Commission to relook into the matter and take follow up action to be taken on urgent basis to remove the low voltage problem and furnish the report as per the Commission's order dated 19.06.2009 on or before 31.12.2009.
- 3. As per the above direction of the Commission, a joint verification report was made on 12.09.2009 by the Technical Team and pursuant to that report power transformer capacity was up graded from 5 MVA to 8 MVA since 27.04.2011. There was installation of one 25 KVA S/S at the tail end side of the village Khalapal to share the load of existing 63 KVA S/S which had been upgraded to 100 KVA S/S under DESI

Scheme for better voltage profile. Now the consumers of the said village along with the petitioner herein are getting voltage upto 213 volts at consumer side which was verified by the MRT staff on 11.05.2016 in the presence of the representative of the petitioners.

4. Therefore, the order dated 24.06.2008 passed by the GRF, Jajpur in C.C.Case No. 129/2008 and the order dated 12.11.2008 of the Ombudsman-II passed in C.R.Case No. OM (II)-13/2008 have been complied with by the respondents and there is no need to proceed further in the above case. Hence the proceeding under Section 142, 146 and 147 of Electricity Act, 2003 are dropped.

Sd/-Sd/-Sd/-(A.K. Das)(S.P. Swain)(S.P.Nanda)MemberMemberChairperson