
Case No. 139/2010

E.E (Elect.), NED, WESCO Respondent

2. According to the directions of the Commission vide order dated 21.11.2011, the respondents have submitted that they have taken steps for revision of the bills of the petitioner and are removing the voltage problems and power interruption. Now the voltage profile of the petitioner is as per voltage under guaranteed standards of performance of the OERC's Regulation. The Respondent No-2 (OPTCL) has already submitted the status of progress with regards to execution of 132/33 KV Nuapada grid S/S. The associated 132 KV lines from Khariar to Nuapada has been energized and commissioned with one 132/33 KV, 20 MVA transformer on 27.12.2014. The 2nd 132/33 KV, 20 MVA transformer has also been commissioned on 23.05.2015.

3. Since the order of the GRF, Bolangir in C. C. Case No. 104/2010 and so also order of the OERC dated 21.01.2011 has been complied with by the respondents, there is no need to proceed further in the above case.
4. Accordingly, the Section 142 proceeding under the Electricity Act, 2003 is dropped.

Sd/-
(A.K. Das)
Member

Sd/-
(S.P. Swain)
Member

Sd/-
(S.P.Nanda)
Chairperson